

in accordance with Comm 85, Wis. Adm. Code

Attach complete site plan on paper not less than 8 1/2 x 11 inches in size. Plan must include, but not limited to: vertical and horizontal reference point (BM), direction and percent slope, scale or dimensions, north arrow, and location and distance to nearest road.

Please print all information.

Personal information you provide may be used for secondary purposes (Privacy Law, s. 15.04 (1) (m)).

County	WASHINGTON
Parcel I.D.	
Reviewed by	Date
<i>D. J. Seal</i>	11/10/07

Property Owner	RICHARD WEGNER WASHINGTON COUNTY PLANNING AND PARKS DEPT	Property Location	Govt. Lot <u>SE</u> 1/4 <u>SE</u> 1/4 S 34 T 9 N R 19 E (PPAW)
Property Owner's Mailing Address	107 NOB Hill Dr	Lot #	Block #
City	COUGATE WI 53017	Subd. Name or CSM#	
State	WI	City	RICHFIELD
Zip Code	53017	Village	
Phone Number	(262) 628-1747	Town	
		Nearest Road	NW Cor NOB Hill Dr W + QUEENS CT

New Construction Use: Residential / Number of bedrooms ? Code derived design flow rate _____ GPD

Replacement Public or commercial - Describe: _____

Parent material _____ Flood Plain elevation if applicable _____ ft.

General comments and recommendations: MOUND LR. 0.4 - 0.6

1 Boring # Boring Pit Ground surface elev. 100.0 ft. Depth to limiting factor 34 in.

Horizon	Depth in.	Dominant Color Munsell	Redox Description Qu. Sz. Cont. Color	Texture	Structure Gr. Sz. Sh.	Consistence	Boundary	Roots	Soil Application Rate GPD/ft	
									*Eff#1	*Eff#2
Ap	0-13	10YR 3/3	—	SIL	2FSBK	MFR	CW	2F, 1M, 1C	0.6	0.8
B	13-24	10YR 5/3	—	SIL	1FSBK	MFR	CW	2F, 1M	0.4	0.6
B	24-34	7.5YR 4/4	—	CL	2FABK	MFR	CW	1F, 1M	0.4	0.6
BC	34-60	7.5YR 4/4	old spots 7.5YR 5/8	GCL	OM	MFR	AW	1F	0.0	0.0
C	60-96	10YR 4/4	field spots 7.5YR 5/8	VCBL SILG	OM	MFR	—	—	0.0	0.2

2 Boring # Boring Pit Ground surface elev. 98.1 ft. Depth to limiting factor >54 in.

Horizon	Depth in.	Dominant Color Munsell	Redox Description Qu. Sz. Cont. Color	Texture	Structure Gr. Sz. Sh.	Consistence	Boundary	Roots	Soil Application Rate GPD/ft	
									*Eff#1	*Eff#2
Ap	0-12	10YR 3/3	—	SIL	2FSBK	MFR	CW	2F, 2M, 1C	0.6	0.8
B	12-30	7.5YR 4/4	—	GCL	2FABK	MFR	AW	2F, 2M	0.4	0.6
C	30-54	10YR 5/4	—	GFSL LFS	OM	MFR	—	1F	0.2	0.5

* Effluent #1 = BOD₅ > 30 ≤ 220 mg/L and TSS > 30 ≤ 150 mg/L
* Effluent #2 = BOD₅ ≤ 30 mg/L and TSS ≤ 30 mg/L

CST Name (Please Print)	Signature	CST Number
ANN CATALDO	<i>[Signature]</i>	245389
Address	Date Evaluation Conducted	Telephone Number
514 W33511 Hwy 18 DELAWARE WI 53018	10-6-06	262 948 2550

Property Owner WEGNER

Parcel ID # NOB HLE DR

Page 2 of 3

3 Boring # Boring Pit Ground surface elev. 96.2 ft. Depth to limiting factor 24 in.

Horizon	Depth in.	Dominant Color Munsell	Redox Description Qu. Sz. Cont. Color	Texture	Structure Gr. Sz. Sh.	Consistence	Boundary	Roots	Soil Application Rate GPD/ft	
									*Eff#1	*Eff#2
Ap	0-10	10YR 5/3	—	SIL	2FSBK	MFR	CW	2F, 2M, 1C	0.6	0.8
B	10-15	7.5YR 4/4	—	CL	2FSBK	MFR	CW	2F, 1M, 1C	0.4	0.6
BC	15-24	7.5YR 4/4	—	GCL	1FSBK	MFR	AW	1F, 1M	0.2	0.3
C	24-40	10YR 5/4	ClO SPOTS 7.5YR 5/8	SLL, FB	OH	MFR	—	1F	0.0	0.2

4 Boring # Boring Pit Ground surface elev. _____ ft. Depth to limiting factor 0 in.

Horizon	Depth in.	Dominant Color Munsell	Redox Description Qu. Sz. Cont. Color	Texture	Structure Gr. Sz. Sh.	Consistence	Boundary	Roots	Soil Application Rate GPD/ft	
									*Eff#1	*Eff#2
FILL	0-9	10YR 5/4	—	GL	1FSBK	MFR	AW	2F	0.4	0.6
FILL	9-16	10YR 4/3	—	GL	1FSBK	MFR	GW	1F, 1M	0.4	0.6
FILL	16-31	10YR 6/4	ClO SPOTS CaCO ₃ 7.5YR 5/8	SILL	1F-MASK	MFR	—	1F	0.2	0.3

Boring # Boring Pit Ground surface elev. _____ ft. Depth to limiting factor _____ in.

Horizon	Depth in.	Dominant Color Munsell	Redox Description Qu. Sz. Cont. Color	Texture	Structure Gr. Sz. Sh.	Consistence	Boundary	Roots	Soil Application Rate GPD/ft	
									*Eff#1	*Eff#2


* Effluent #1 = BOD₅ > 30 ≤ 220 mg/L and TSS > 30 ≤ 150 mg/L

* Effluent #2 = BOD₅ ≤ 30 mg/L and TSS ≤ 30 mg/L

The Department of Commerce is an equal opportunity service provider and employer. If you need assistance to access services or need material in an alternate format, please contact the department at 608-266-3151 or TTY 608-264-8777.

RAY HILDEBRAND SURVEYORS, INC.

W202 N10418 Appleton Avenue
 GERMANTOWN, WISCONSIN 53022
 Phone 251-2507



X-X = GUTTER
 = 75' LWB
 = 98.1' B.L.

SCALE 1" = 50'

DESCRIPTION

That part of the S. E. 1/4 of Section 34, T9N - R19E, Town of Richfield, Washington County, Wisconsin, bounded and described as follows:

Beginning at the most easterly corner of Lot 1, NOB HILL WEST, a subn of part of the S. E. 1/4 of said section; thence N. $86^{\circ} 30' E$, on the southerly R/W of Queen's Court 167.75 feet, thence N. $70^{\circ} 40' E$, on said R/W 34.00 feet, thence southerly on the arc of a curve on the westerly R/W of Nob Hill Drive West 214.63 feet (Chd brg S. $13^{\circ} 22' E$, 212.69 feet, R = 460.00 feet, IA = $26^{\circ} 44'$), thence S. $84^{\circ} 19' 30'' W$, 287.67 feet, thence N. $47^{\circ} 08' 30'' W$ - 40.00 feet, thence N. $01^{\circ} 10' 37'' E$ - 176.82 feet, thence N. $82^{\circ} 57' 15'' E$, on the southerly line of said Lot 1 - 66.49 feet to the point of beginning.